



Drawing not to scale

MODEL #		Transformer Typical Installation Detail	
CP900SSMT		NOTES: <ul style="list-style-type: none"> • Make sure home run wires are tight in the terminal blocks. Loose/poor connections will melt the block and damage the transformer. • Field repairable breakers, terminals, timer and photocell. • For transformer sizing see CAST "Transformer and System Installation Guide" • For transformer mounting information see "Transformer Stand Detail". 	
POWER PRO SERIES			
Rev. 1-13-05	Plan Symbol: T		